



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Parliament House**  
100 Spring St East Melbourne  
Contract No: P3058

**Callouts: 22548**

Date of Call: 10-12-2018 14:47:24  
Time of Arrival: 10-12-2018 16:00:00  
Rectification Time: 10-12-2018 16:50:00  
Time of Departure: 10-12-2018 17:10:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Playing Up

**For Lift(s):** 3

**For Floor(s):** 1

**Call Description:** lift is playing up

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Door Lock Faulty

**Work Action (CORRECTION):** Adjust Doors/Locks

**Work Description:** Landing door roller out of adjustment re adjusted door roller and tested

**Part Required:** No Parts Required

**Service Technician**

Graeme Gathercole

**Report Customer**

Andrew