



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Aurora (582 St Kilda Rd, Melbourne)
582 St Kilda Rd Melbourne
Contract No: P3402

Callouts:

Date of Call: 14-11-2018 19:40:00
Time of Arrival: 14-11-2018 20:35:00
Rectification Time: 14-11-2018 21:30:00
Time of Departure: 14-11-2018 21:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2

For Floor(s): 4

Call Description: Swp

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Contactor

Work Action (CORRECTION): Replace/Repair Reply or Contactor

Work Description: Release passenger\r\nSb fault logged\r\nFound high resistant contacts on sb1 contactor \r\nReplaced contactor with new \r\nTest operation\r\n

Part Required: 110v seimens contactor\r\nSeimens Auxillary block 2no/2nc\r\n

Service Technician

Matt Grieger

Report Customer