



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Bentleigh

metro centre rd & nicholson st Bentleigh

Contract No: P3624

Callouts ID:

Date of Call: 23-10-2018 8:02:00

Time of Arrival: 23-10-2018 8:50:00

Rectification Time: 23-10-2018 9:25:00

Time of Departure: 23-10-2018 9:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): p

Call Description: Lift ooo

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Contactor

Work Action (CORRECTION): Replace/Repair Reply or Contactor

Work Description: Lift had kmy error linked to proving auxiliary.\r\nReplace auxiliary proving circuit.\r\nAlso re terminate input and output for kmy contact on main board.\r\nAlso test kmy main contacts\r\nTested and return lift to service

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0