



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Wales Corner**  
227 Collins St Melbourne  
Contract No: P3291

## Callouts: 22561

Date of Call: 11-12-2018 11:23:04  
Time of Arrival: 11-12-2018 12:00:00  
Rectification Time: 11-12-2018 12:30:00  
Time of Departure: 11-12-2018 12:40:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** 8

**Call Description:** OOO

**Order Number:** .

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Error Log Fault

**Work Action (CORRECTION):** Reset Control System

**Work Description:** Error code 36 checked operation of KMY and KMC contactors no fault found

**Part Required:** No Parts Required

**Service Technician**

Graeme Gathercole

**Report Customer**

.