



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Elm Apartments
22 Dorcas St South Melbourne
Contract No: P3445

Callouts ID: 22070

Date of Call: 23-10-2018 8:45:00
Time of Arrival: 23-10-2018 9:10:00
Rectification Time: 24-10-2018 9:30:00
Time of Departure: 23-10-2018 10:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 3

For Floor(s): .

Call Description: Person was stuck in lift, now released. Running as per usual. Emergency call button might not be working as it did not go to united lifts.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Tested lift phone and operation of lift all ok \r\nWhile on site checked lift 3 door noise motor bearing to be replaced

Part Required: New bearing

Service Technician

Brad Stellini

Report Customer

Michael 0403 127 470