



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Riggall St 61

61 Riggall Street Broadmeadows

Contract No: P3608

Callouts: 22147

Date of Call: 31-10-2018 12:44:19

Time of Arrival: 31-10-2018 14:57:00

Rectification Time: 31-10-2018 16:19:00

Time of Departure: 31-10-2018 16:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): 5

Call Description: A lady was stuck inside, called for help, tenant outside heard and pressed the call button. She was let out. Now small lift isn't opening on 4th fl

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Car safety out. Rectified, run and tested for operation. Returned to service

Part Required: No Parts Required

Service Technician

James Wallace

Report Customer

.