



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Brimbank City Council
2-8 Dawson Street Sunshine West
Contract No: P3630

Callouts: 22536

Date of Call: 11-12-2018 10:00:00
Time of Arrival: 11-12-2018 11:00:00
Rectification Time: 11-12-2018 11:30:00
Time of Departure: 11-12-2018 12:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): g

Call Description: lift is out of order on ground floor with doors open

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Lock fly on G floor. Rectify

Part Required: No Parts Required

Service Technician

mat tehan

Report Customer

.