



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Glenhuntly Rd 242, Elsternwick
242 Glenhuntly Rd Elsternwick
Contract No: P3449

Callouts:

Date of Call: 17-11-2018 20:56:00
Time of Arrival: 17-11-2018 21:36:00
Rectification Time: 17-11-2018 22:30:00
Time of Departure: 17-11-2018 22:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2

For Floor(s): -1

Call Description: 2 people stuck

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Passengers out of lift on arrival,\r\nlift stuck on lowest landing -1\r\n20mm below floor level,\r\nsuspect faulty releve circuit need to investigate further,\r\nswitched lift off for weekend.\r\nnotified building manager.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Kosta