



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Tower 3

70 Lorimer Street Docklands

Contract No: P3671

Callouts:

Date of Call: 18-11-2018 0:36:00

Time of Arrival: 18-11-2018 1:05:00

Rectification Time: 18-11-2018 1:30:00

Time of Departure: 18-11-2018 1:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): W2

For Floor(s): 2

Call Description: reported 6 passenger\'s stuck in lift

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): See Work description

Work Description: lift running on arrival \r\nlift was overloaded with 14 passengers not 6 as reported, passengers pulled doors open.\r\nchecked operation lift run normal.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

peter kelly