



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Dandenong
Metro Foster Street Dandenong
Contract No: W3677

Callouts:

Date of Call: 24-12-2018 17:29:00
Time of Arrival: 24-12-2018 17:29:00
Rectification Time: 24-12-2018 19:22:00
Time of Departure: 24-12-2018 19:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): P

Call Description: Trapped passenger

Order Number: 660550

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Passengers out on arrival. Doors and locks required adjusting after being hit with electric wheelchair. Adjusted landing doors, car doors, lock contacts, and lock rollers. Run and tested and returned to service

Part Required: No Parts Required

Service Technician

James Wallace

Report Customer

.