



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Cambridge St 134, Collingwood  
134 Cambridge St Collingwood  
Contract No: P3195

## Callouts: 22307

Date of Call: 16-11-2018 11:25:11  
Time of Arrival: 16-11-2018 11:45:00  
Rectification Time: 16-11-2018 12:10:00  
Time of Departure: 16-11-2018 12:15:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** S.W.P

**For Lift(s):** 1

**For Floor(s):** 2

**Call Description:** person stuck in lift

**Order Number:** \*

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Door Lock Faulty

**Work Action (CORRECTION):** Adjust Doors/Locks

**Work Description:** Door lock contact faulty, cleaned and replaced contacts. Returned to service.

**Part Required:** No Parts Required

**Service Technician**

Nathan Downton

**Report Customer**

0447 004 553