



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Albert Redevelopment  
140 Albert Road South Melbourne  
Contract No: W3688

**Callouts ID: 22130**

Date of Call: 29-10-2018 11:31:10  
Time of Arrival: 29-10-2018 13:00:00  
Rectification Time: 29-10-2018 13:30:00  
Time of Departure: 29-10-2018 14:10:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Doors Closed

**For Lift(s):** 1

**For Floor(s):** 12

**Call Description:** doors open on every other level except level 12

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift floor level out of adjustment \r\nAdjusted floor level plate ran and tested

**Part Required:** No Parts Required

**Service Technician**

Brad Stellini

**Report Customer**

.