



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Gascoigne**

879 - 881 Dandenong road Malvern east

Contract No: P3625

**Callouts: 22568**

Date of Call: 12-12-2018 9:28:39

Time of Arrival: 12-12-2018 9:45:00

Rectification Time: 12-12-2018 10:00:00

Time of Departure: 12-12-2018 10:20:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Doors Closed

**For Lift(s):** 2

**For Floor(s):** B1

**Call Description:** car lift stuck on B1 with doors closed.

**Order Number:** 0

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift had error 47 contactors jammed fault. Check main contactors and other relays in circuit and watched lift. Did not fault.  
Tighten and check wires in proving circuit as these can cause errors related to this fault.

**Part Required:** No Parts Required

**Service Technician**

Zane Tregurtha

**Report Customer**

Matt (residence) 0413 416 225