



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Metro Nunawading

Metro Nunawading Station Nunawading

Contract No: P3586

Maintenance:

Date of Call: 03-01-2019

Time of Arrival: 14:37:00

Time of Departure: 14:37:00

Maintenance Details

Maintenance Description: Regular service

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Test all car safties	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check tuning ajustments	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y
check brake operation rope brake and associated equipment	Y	Y
Check pit equipment and check water for pit	Y	Y
Check trailer flexes, attachments running clearance	Y	Y
Test Emergency Light Unit	Y	Y
Test Lift Communications	Y	Y

Service Technician

Zane Tregurtha

Customer Email