



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Jones Lang LaSalle
401 Collins St Melbourne
Contract No: P3216

Callouts ID: 21988

Date of Call: 15-10-2018 10:14:05
Time of Arrival: 15-10-2018 10:35:00
Rectification Time: 15-10-2018 14:45:00
Time of Departure: 15-10-2018 16:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 3

For Floor(s): 8

Call Description: Goods lift is out of order. Want someone to attend immediately.\r\nReported by: Saju (JLL) 0435 738 090

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift on level 8,\r\nfound brake error fault,\r\nstripped down brake and replaced seals\r\nreadjusted and checked operation \r\nreturned lift back to service notified building management.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

saju