



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Cardinia Shire Council
20 Siding Ave Officer
Contract No: P3488

Maintenance:

Date of Call: 31-10-2018
Time of Arrival: 9:15:00
Time of Departure: 10:00:00

Maintenance Details

Maintenance Description: Routine maintenance

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Test all car safties	Y	Y
Clean & Check all M/R Equipment	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check tuning ajustments	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
check brake operation rope brake and associated equipment	Y	Y
Check pit equipment and check water for pit	Y	Y
Check trailer flexes, attachments running clearance	Y	Y
Fire Service Operation Test	Y	Y
Test Emergency Light Unit	Y	Y
Test Lift Communications	Y	Y

Service Technician

Kevin Wilkins

Customer Email

peterv@campeyngroup.com.au