



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

4 Dudley St
4 Dudley st Brighton
Contract No: P3576

Maintenance:

Date of Call: 19-12-2018
Time of Arrival: 14:40:00
Time of Departure: 15:40:00

Maintenance Details

Maintenance Description: Routine maintenance. 1 x light out in rear lift, no spare globes left in the motor room. Slight evidence of water in both lift pits after recent heavy rain, I would expect this to dry without assistance in the next week.

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Test all car safties	Y	Y
Clean & Check all M/R Equipment	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check tuning ajustments	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y
Check all safety switches, limits in lift well	Y	Y
Check pit equipment and check water for pit	Y	Y
Check hydrolic tank oil level, valves RAM etc	Y	Y
Test Emergency Light Unit	Y	Y
Test Lift Communications	Y	Y

Service Technician

Kevin Wilkins

Customer Email

sanctumoc@gmail.com; spconnect@strataplan.com.au