



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Thomastown

Metro Thomastown Station Thomastown

Contract No: P3589

Callouts: 22575

Date of Call: 12-12-2018 12:38:16

Time of Arrival: 12-12-2018 12:56:00

Rectification Time: 12-12-2018 13:34:00

Time of Departure: 12-12-2018 13:38:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): #

Call Description: lift is stuck between floors

Order Number: 02AA603298

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift safety gear switch tripped. Re adjusted and returned to service.

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

Siobhan 96191109