



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
03 9687 9099  
info@unitedlifts.com.au

Customer Details:

**Kew Pumping Station - Melbourne Water**  
- Bourke Road Kew  
Contract No: B3747

## Maintenance:

Date of Call: 20-11-2018  
Time of Arrival: 8:00:00  
Time of Departure: 9:00:00

### Maintenance Details

**Maintenance Description:** Regular service \r\nGrease drive sheave and governor\r\nTop up gear box still leaking badly requires new seal.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Lubricate All Sheaves	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check and ajust car & cwt guide shoes	Y
Check pit equipment and check water for pit	Y
Check trailer flexes, attachments running clearance	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

**Service Technician**

Zane Tregurtha

**Customer Email**

caroline@unitedlifts.com.au