



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Depot
98 QUEENS AVE CAULFIELD EAST
Contract No: P3634

Callouts:

Date of Call: 19-12-2018 22:00:00
Time of Arrival: 19-12-2018 23:25:00
Rectification Time: 19-12-2018 23:40:00
Time of Departure: 20-12-2018 0:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): G

Call Description: Lift 000 on G with doors open

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Found G landing lock not made and 54 fault. Clean door tracks and headers, clean lock and test - ok.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

.