



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Elizabeth St 191, Richmond (Building B)
191 Elizabeth St Richmond (Building B)
Contract No: P3547

Callouts ID: 22089

Date of Call: 24-10-2018 12:48:09
Time of Arrival: 24-10-2018 13:15:00
Rectification Time: 24-10-2018 14:00:00
Time of Departure: 24-10-2018 14:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Noisy

For Lift(s): 1

For Floor(s): *

Call Description: making high pitch noises when going up and down

Order Number: 15287

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found brake clearance not sufficient. Pads still touching while in motion. Adjusted clearance and returned to service. Tested ok.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

Jay from Jacobs group