



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Melrose St 159, North Melbourne  
159 Melrose St North Melbourne  
Contract No: P3429

## Callouts ID:

Date of Call: 12-10-2018 20:24:00  
Time of Arrival: 12-10-2018 20:45:00  
Rectification Time: 12-10-2018 20:55:00  
Time of Departure: 12-10-2018 21:00:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** 7

**Call Description:** Lift 2 o.o.o doors closed level 7

**Order Number:** 15123

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Rope Brake Tripped

**Work Action (CORRECTION):** See Work description

**Work Description:** Found rope brake tripped. Reset and returned to service.

**Part Required:** No Parts Required

**Service Technician**

Nathan Downton

**Report Customer**

\*