



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Melbourne
27 King St Melbourne
Contract No: P3304

Callouts:

Date of Call: 07-11-2018 9:30:00
Time of Arrival: 07-11-2018 9:30:00
Rectification Time: 07-11-2018 11:30:00
Time of Departure: 07-11-2018 11:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Chargeable Callout

For Lift(s): 1

For Floor(s): g

Call Description: Lift shutdown on the 6/11/2018 at 15:02\r\ndue to water damage.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Checked all lift equipment for water damage, several items to be replaced,\r\ndried up affect areas returned lift back to service monitoring lift operation notified building management.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Adriana