



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Gardiner

Metro Gardiner Station Glen Iris

Contract No: P3618

Callouts:

Date of Call: 16-12-2018 19:20:00
Time of Arrival: 16-12-2018 20:00:00
Rectification Time: 16-12-2018 21:00:00
Time of Departure: 16-12-2018 21:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1,2

For Floor(s):

Call Description: No lights in both lifts and lift 2 ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Main Circuit Braker Tripped

Work Action (CORRECTION): See Work description

Work Description: Lift 1 car light and power cb tripped \r\nLift 2 car light and power + ard cb tripped\r\nSuspect power surge/issue in area with this weather
\r\nSuspect faulty ups lift 2 as no lights working. To be addressed tomorrow

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer