



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro McKinnon
Metro McKinnon McKinnon
Contract No: P3623

Callouts: 22701

Date of Call: 24-12-2018 11:54:07
Time of Arrival: 24-12-2018 13:00:00
Rectification Time: 24-12-2018 13:20:00
Time of Departure: 24-12-2018 13:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1

For Floor(s): *

Call Description: red emergency button is not working

Order Number: MCK459

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Emergency phone not working. Found 1x8 circuit breaker tripped. Reset. Tested phone. Working ok. Returned to service.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

Ming 9610 6166