



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Hoddle St 253, Collingwood
253 Hoddle St Collingwood
Contract No: P3434

Callouts:

Date of Call: 06-11-2018 18:33:00
Time of Arrival: 06-11-2018 18:45:00
Rectification Time: 06-11-2018 19:40:00
Time of Departure: 06-11-2018 19:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): 2

Call Description: Water in lift

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Level 2 flooded\r\nWater ran down on top of lift car covering all equipment on front of cars + floors below and pit equipment \r\nCp2 breaker controller tripped\r\nShut down\r\n\r\nSuspect water damage also on lift 2 just unable to check as only lift operational

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer