



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Elsternwick

Metro Elsternwick Station Elsternwick

Contract No: P3585

Callouts:

Date of Call: 16-12-2018 8:00:00

Time of Arrival: 16-12-2018 9:45:00

Rectification Time: 16-12-2018 10:15:00

Time of Departure: 16-12-2018 10:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 2

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Fuse Blown

Work Action (CORRECTION): Replace/Reset Fuse

Work Description: F1 1a fuse before start of safety chain blown\r\nLift had water in pit previous days suspect cause \r\nReplaced fuse and test operation\r\nChecked any current signs of water or causes

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer