



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Batman's Hill on Collins
623 Collins Street Melbourne
Contract No: P3681

Callouts ID: 22078

Date of Call: 23-10-2018 14:26:48
Time of Arrival: 23-10-2018 16:59:00
Rectification Time: 23-10-2018 17:55:00
Time of Departure: 23-10-2018 18:01:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 6

For Floor(s): 2

Call Description: lift is out of order on level 2, doors are closed

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Replane 61N cigar switch. Run and rested. Returned to service

Part Required: No Parts Required

Service Technician

James Wallace

Report Customer

.