

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 03 9687 9099 info@unitedlifts.com.au

Customer Details:
Metro Offices Burnley
225 Coppin St Burnley
Contract No: P3580

Maintenance:

Date of Call: 21-12-2018 Time of Arrival: 13:30:00 Time of Departure: 14:00:00

Maintenance Details

Maintenance Description: Routine maintenance

Maintenance Task	Lift 1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Lubricate All Sheaves	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check pit equipment and check water for pit	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Customer Email

Nathan Downton