



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Cambridge Street 21
21 Cambridge Street Box Hill
Contract No: B3675

Callouts: 22152

Date of Call: 31-10-2018 14:30:49
Time of Arrival: 31-10-2018 15:30:00
Rectification Time: 31-10-2018 15:40:00
Time of Departure: 31-10-2018 16:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: lift is out order

Order Number: 087586

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift out of order with fault 20. \r\nCheck all fault information and causes, potential cause for this error can be phase loss (power disturbance). lift and tested ok.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0