



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Batman's Hill on Collins
623 Collins Street Melbourne
Contract No: P3681

Callouts: 22292

Date of Call: 15-11-2018 10:00:52
Time of Arrival: 15-11-2018 13:30:00
Rectification Time: 15-11-2018 15:30:00
Time of Departure: 15-11-2018 15:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Opening And Closing

For Lift(s): 6

For Floor(s): 5

Call Description: lift is getting stuck on all levels

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Error 77 and 44 on LCE display \r\nsuspect faulty car door operator PCB \r\nto be replaced notified building manager Mark.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Mark