



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Hoddle St 253, Collingwood
253 Hoddle St Collingwood
Contract No: P3434

Callouts:

Date of Call: 27-12-2018 22:13:00
Time of Arrival: 27-12-2018 22:30:00
Rectification Time: 27-12-2018 22:45:00
Time of Departure: 27-12-2018 23:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 10

Call Description: Ooo doors open

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Brakes

Work Action (CORRECTION): Adjust Brake/Switches

Work Description: Error 38 brake switch error\r\nFound one brake switch out of position and not in correct state\r\nRe position and test operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer