



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Melbourne Water
87-89 Millers Road Brooklyn
Contract No: B3747

Maintenance ID:

Date of Call: 17-10-2018
Time of Arrival: 9:30:00
Time of Departure: 13:30:00

Maintenance Details

Maintenance Description: Routine service \r\nReprogram lift emergency phones as instructed\r\nSafety gear test slow speed only\r\nElu test both fail - will quote for new units\r\nWill quote for car door skirt which was off

Maintenance Task	3	4	5
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y
Test all car safties	Y	Y	Y
Clean & Check all M/R Equipment	Y	Y	Y
Clean out controller ad check operation of various parts.	Y	Y	Y
Clean & check landing door equipment	Y	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y	Y
Check pit equipment and check water for pit	Y	Y	Y
Safety gear full performance test	Y	Y	Y
Report any major rapirs	Y	Y	Y
Test Emergency Light Unit	Y	Y	Y
Test Lift Communications	Y	Y	Y

Service Technician

Matt Grieger

Customer Email

caroline@unitedlifts.com.au