



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

City Gate Hotel/Doubletree
270 Flinders St Melbourne
Contract No: P3103

Callouts: 22448

Date of Call: 30-11-2018 14:59:55
Time of Arrival: 30-11-2018 15:15:00
Rectification Time: 30-11-2018 16:20:00
Time of Departure: 30-11-2018 16:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 4

For Floor(s): 11

Call Description: lift is stuck on level 11

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Error code 6 cleaned and checked CDS and 11th floor landing door locks

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

.