



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Melbourne Water
87-89 Millers Road Brooklyn
Contract No: B3747

Callouts: 22672

Date of Call: 19-12-2018 18:00:59
Time of Arrival: 20-12-2018 13:30:00
Rectification Time: 20-12-2018 13:30:00
Time of Departure: 20-12-2018 15:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 3

For Floor(s):

Call Description: Lift had passenger stuck but is now released, please attend in the morning to rectify ongoing issue

Order Number: WO4163906

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): Check Operation

Work Description: Lift roa\r\nAs lift reset unable to determine which fault logged was the one the caused entrapment \r\nCheck error log via hand tool\r\nOrgan
quote for replacement of contactors in controller

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer

Ross