



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Mernda Station
0 Bridge Inn Road South Morang
Contract No: W3696

Callouts:

Date of Call: 03-12-2018 4:11:00
Time of Arrival: 03-12-2018 5:11:00
Rectification Time: 03-12-2018 5:35:00
Time of Departure: 03-12-2018 6:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 3

For Floor(s): G

Call Description: Lift stopped doors open.

Order Number: 659517

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Reset Control System

Work Description: Lock differential fault, clean door hanger tracks and check door sill. Reset lift controls and monitor

Part Required: No Parts Required

Service Technician

Daniel Barry

Report Customer

.