



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Clifford Terrace 78, Kensington
78 Clifford Terrace Kensington
Contract No: P3423

Callouts:

Date of Call: 25-12-2018 20:32:00
Time of Arrival: 25-12-2018 21:50:00
Rectification Time: 25-12-2018 22:05:00
Time of Departure: 25-12-2018 22:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 2

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): See Work description

Work Description: Fatl error 11 fc block and error 707\r\nCheck contactors in controller all ok\r\nBattery faulty in controller to be replaced\r\nReset fatl and test operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer