



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nicholson Street 141, Carlton
141 Nicholson St Carlton
Contract No: P3118

Callouts:

Date of Call: 30-12-2018 19:23:00
Time of Arrival: 30-12-2018 20:05:00
Rectification Time: 30-12-2018 20:30:00
Time of Departure: 30-12-2018 20:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Opening And Closing

For Lift(s): 2

For Floor(s): 14

Call Description: Indicator panel off. Doors opening and closing.

Order Number: 16375

DESCRIPTION OF WORK

Fault Found (CAUSE): Car Gate Switch Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Car door switch not closing. \r\nAdjusted door switch.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

x