

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
King St 27, Prahran
27 King St Prahran
Contract No: P3433

Callouts:

Date of Call: 01-12-2018 16:57:00 Time of Arrival: 01-12-2018 17:30:00 Rectification Time: 01-12-2018 5:55:00 Time of Departure: 01-12-2018 18:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): G

Call Description: Lift stopped

Order Number: 15857

DESCRIPTION OF WORK

Fault Found (CAUSE): Rope Brake Tripped

Work Action (CORRECTION): Reset Control System

Work Description: Lift rope break tripped, reset. Check locks and safties and return to service.

Part Required: No Parts Required

Service Technician Report Customer

Daniel Barry