



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Pegasus Suites Hotel
206-216 A'Beckett St Melbourne
Contract No: P3382

Callouts: 22186

Date of Call: 05-11-2018 8:36:00
Time of Arrival: 05-11-2018 9:00:00
Rectification Time: 05-11-2018 9:34:00
Time of Departure: 05-11-2018 9:38:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 4

For Floor(s): 16

Call Description: stuck on level 16 with doors closed.

Order Number: #

DESCRIPTION OF WORK

Fault Found (CAUSE): Overload Tripped

Work Action (CORRECTION): Reset Key Switch

Work Description: Key switch tripped. Reset and run lift

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

Nickolas 9284 2400