



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

1 Powlett Street  
1 Powlett Street East Melbourne  
Contract No: P3609

## Callouts ID: 22025

Date of Call: 18-10-2018 13:26:58  
Time of Arrival: 18-10-2018 13:40:00  
Rectification Time: 18-10-2018 13:50:00  
Time of Departure: 18-10-2018 13:59:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** p1

**Call Description:** lift is out of order

**Order Number:** \*

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Doors out of mesh on level p1. Adjusted lock roller for further cam penetration, returned doors to mesh. Returned to service.

**Part Required:** No Parts Required

**Service Technician**

Nathan Downton

**Report Customer**

\*