



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

La Trobe St 171, Melbourne
171 La Trobe St Melbourne
Contract No: P3391

Callouts: 22438

Date of Call: 29-11-2018 14:57:53
Time of Arrival: 29-11-2018 15:10:00
Rectification Time: 29-11-2018 16:10:00
Time of Departure: 29-11-2018 16:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1,2

For Floor(s): 6

Call Description: both lifts have issues

Order Number: 2739479

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: No1 ROA, checked 6th floor landing door operation. No2 fault cleared checked operation and returned lift to normal service

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

.