



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

St Kilda Rd 622, Melbourne
622 St Kilda Rd Melbourne
Contract No: P3450

Callouts ID:

Date of Call: 21-10-2018 7:25:00
Time of Arrival: 21-10-2018 8:55:00
Rectification Time: 22-10-2018 9:14:00
Time of Departure: 21-10-2018 9:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 1

Call Description: Lift ooo

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Govenor Tripped

Work Action (CORRECTION): Reset/Adjust Switch

Work Description: Lift ooo, found govner switch tripped\r\nReset and checked running operation of lift

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

.