



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Cooke Crt 3, Richmond (Building D - West Block)
3 Cooke Crt Richmond (Building D - West Block)
Contract No: P3549

Callouts: 22514

Date of Call: 07-12-2018 15:40:28
Time of Arrival: 07-12-2018 16:36:00
Rectification Time: 07-12-2018 17:20:00
Time of Departure: 07-12-2018 17:36:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): West Lift

For Floor(s): basement

Call Description: lift is out of order with doors closed, stuck on basement

Order Number: 15981

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift door lock needed correcting as possibly damaged.. rectified issue and returned to service.

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

#