



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

CFMEU

540 Elizabeth St Melbourne

Contract No: P3308

Callouts: 22425

Date of Call: 28-11-2018 14:05:14

Time of Arrival: 29-11-2018 11:30:00

Rectification Time: 29-11-2018 14:30:00

Time of Departure: 29-11-2018 14:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Jerking

For Lift(s): 1,2

For Floor(s): .

Call Description: both lifts are shuddering between floors, also stopping without being called to different levels

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: lift 2 running normal no fault found
lift 1 door lock error code 2
checked all landing door locks on all levels
checked kad and kad1 r
contacts N/O
no new recorded errors notified Michele Ciavarella site manager

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Shaun 0424140112