



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Caulfield Hospital
260 Kooyang Road Caulfield
Contract No: 3565

Callouts ID: 20737

Date of Call: 13-06-2018 9:42:17
Time of Arrival: 13-06-2018 13:23:00
Rectification Time: 13-06-2018 14:24:00
Time of Departure: 13-06-2018 14:39:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): g

Call Description: lift motor room, liquid over floor including oil

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift motor room had a small oil spill on motor room floor cleaned up oil and tank, layed some oil prevention

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

eng