



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Tower 2

60 Lorimer Street Docklands

Contract No: P3671

Callouts: 22166

Date of Call: 02-11-2018 10:27:36

Time of Arrival: 02-11-2018 11:30:00

Rectification Time: 02-11-2018 12:30:00

Time of Departure: 27-11-2018 12:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Not Stopping Level

For Lift(s): E2

For Floor(s): 19

Call Description: lift not leveling

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Adjusted floor levels ran and tested

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

.