



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

CSR Gyprok  
277 Whitehall St Yarraville  
Contract No: P3313

## Callouts ID:

Date of Call: 15-10-2018 13:20:00  
Time of Arrival: 15-10-2018 14:30:00  
Rectification Time: 15-10-2018 14:45:00  
Time of Departure: 15-10-2018 15:00:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** 4

**Call Description:** Ooo

**Order Number:**

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Lift Overloaded

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift overloaded moving bulk materials\r\nSeveral bags with 1200kg weight tags ( have been heavier in past than whats stated )\r\nWeight of material, crates, forklift and person exceeds max weight load

**Part Required:** No Parts Required

**Service Technician**

Matt Grieger

**Report Customer**

diego