



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Werribee Mansion (Sofitel Hotel & Spa)
0 K Rd Werribee
Contract No: P3088

Callouts: 22403

Date of Call: 26-11-2018 15:56:26
Time of Arrival: 26-11-2018 17:50:00
Rectification Time: 26-11-2018 18:30:00
Time of Departure: 26-11-2018 18:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 3

Call Description: lift is out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Car Gate Switch Faulty

Work Action (CORRECTION): See Work description

Work Description: Car gate contact broken needs new one to be replaced. Lift off for night matt g to replace

Part Required: New car gate contact

Service Technician

Brad Stellini

Report Customer

0397314000