



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Caroline Street 41
40 Caroline Street South Yarra
Contract No: W3686

Callouts ID: 22132

Date of Call: 29-10-2018 12:20:32
Time of Arrival: 29-10-2018 13:30:00
Rectification Time: 29-10-2018 15:00:00
Time of Departure: 29-10-2018 15:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): g

Call Description: lift opens directly into apartment without owner's notice

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Report of lift stopping randomly on secured floors, adjust door open limit to lower percentage to stop potential correction run also adjusted cl limit position. Disabled anti nuisance on buttons as advised by tech supervisor\r\nUnable to recreate fault will monitor daily

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

Anguis 0419 571 771